



DNR Report

- The purpose of this statement is to inform all parties involved in the clean up and spill prevention measures that took place at Acme Galvanizing following the March 16th fire.
- *Responsible Parties;*
Acme Galvanizing
2730 S. 19th St
Milwaukee, WI
- *Time of discharge*
March 16th approximately 2pm
- *Location*
2730 S. 19th st
Milwaukee, WI
- *Type and amount*
Est. 3000 gallons fire wash water with small traces of metals. Our sampling as well as the DNR has determined this to be non-hazardous.
- *Brief summary*
Upon arrival we saw the north loading dock full of blue-ish colored water. We then dispatched a crew to remove the water and rinse down the area, in between that time the dock let loose into a nearby water way. It is believed that ice is the only thing that initially held the water. Our suggestion would be to isolate the catch basin in the dock to prevent further releases.

William Binger

I.S Operations Manager

Cell-(414) 397-6493

wbinger@advancedwasteservices.com